

MELBOURNE FIRE DOORS Pty Ltd FIRE DOOR CERTIFICATION CHECK LIST

Date: _____ Reference No. _____

Project: _____

Builder: _____

Installer: _____

Door Locations: _____ LEVELS: _____

Note:- ONE FIRE DOOR TYPE OR LOCATIONS & HARDWARE COMBINATION ONLY PER SHEET


TYPE OF FIRE DOOR (Tick appropriate box)

MAXI <input type="checkbox"/> or MINI <input type="checkbox"/>	FRL-/60/30	FRL-/90/30	FRL-/120/30	FRL-/180/30 or FRL-/240/30
Single Leaf	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Double Leaf	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sliding Door	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

WALL CONSTRUCTION (Tick appropriate box)

Brick	<input type="checkbox"/>	Block	<input type="checkbox"/>	Cast in Concrete	<input type="checkbox"/>
Metal Stud - FR PLASTER	<input type="checkbox"/>	Timber Stud - FR PLASTER	<input type="checkbox"/>	Other (Specify) _____	

FIRE RATED FRAME



Stop Depth (D)	25 or 30mm	<input type="checkbox"/>	15mm	<input type="checkbox"/>
Rebate Width (W)	43 - 51mm	<input type="checkbox"/>	41mm	<input type="checkbox"/>
Frame Backfilled	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
1.4mm Metal Frame	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Back Fill must be done as per AS1905.1 2005			KDHW	<input type="checkbox"/>

FIRE DOORS

Note: All fire rated press metal frames must have at least a 25mm stop

(Maximum Clearance)	Top	<input type="checkbox"/> (3mm)	Side	<input type="checkbox"/> (3mm)	Bottom	<input type="checkbox"/> (10mm)
---------------------	-----	--------------------------------	------	--------------------------------	--------	---------------------------------

Hardware Fitted - (Make and Model to be Listed)

Make & Model of Lock fitted: _____

Make & Model of Closer fitted: _____

Other Hardware fitted: _____

Latch bolt material	Brass	<input type="checkbox"/>	S/Steel	<input type="checkbox"/>	Steel	<input type="checkbox"/>	Other	_____
Striker plate material	Brass	<input type="checkbox"/>	S/Steel	<input type="checkbox"/>	Steel	<input type="checkbox"/>	Other	_____
Lock backset	60mm	<input type="checkbox"/>	70mm	<input type="checkbox"/>	127mm	<input type="checkbox"/>	Other	_____
Closer backcheck fitted	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>				

DOUBLE DOORS

Sequence closing device	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Head latch Fitting	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Clearance between leaves	mm	<input type="checkbox"/>		

SLIDING FIRE DOOR

Clearance Bottom	<input type="checkbox"/> mm	Overlap right side	<input type="checkbox"/> mm	EMHO fitted	<input type="checkbox"/>
Clearance wall - door	<input type="checkbox"/> mm	Overlap left side	<input type="checkbox"/> mm	Track type	<input type="checkbox"/>
Overlap Top	<input type="checkbox"/> mm	Direction of travel fitted	<input type="checkbox"/>	Bracket	<input type="checkbox"/>
Clearance under weight cover	<input type="checkbox"/> mm	(Not less than 150mm from floor)			

The above fire door assemblies have been installed as per the above information

Tags Required	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
---------------	-----	--------------------------	----	--------------------------

Company Name _____ Signed (Installer) _____

Note: It is the responsibility of the installer / Builder to insure that all information recorded on this sheet is correct. The installer / Builder will take sole responsibility of the installation and insure the door operation and finished clearances are in accordance with AS1905.1 for fire rating and complies with the BCA C3.6 - 3.11G . If the information supplied above is found to be incorrect or misleading, MFD will accept no responsibility and tagging & certification may be deemed void.